



香 港 標 準 及 檢 定 中 心
Hong Kong Standards and Testing Centre

Date : 2002-10-09

TEST REPORT

Page 1 of 2

NO: HC117199

APPLICANT: (Code: LIH001)

Lik Hung Metal Works Ltd
G/F 5 Cheung Shun St
Cheung Sha Wan
Kln

Attn: Mr Chan Chi Wah

DESCRIPTION OF SAMPLE(S):

One submitted sample said to be 3 pcs of 225 x 25mm underfloor trunking with 3 compartments made of 1.6mm thickness galvanized steel.

SAMPLE(S) RECEIVED DATE:

2002-09-30

TESTED DATE:

2002-10-03

INVESTIGATION(S) REQUESTED:

BS 4678: Part 2: 1973 - Resistance to corrosion – Class 3 Protection

METHOD(S) USED:

BS 2989: 1982 – Appendix A



Am
Anne Chuah, CFD
For Chief Executive

Conditions in issuance of Test Report

1. This Report is issued in confidence to the client and it will be strictly treated as such by the Hong Kong Standards and Testing Centre Ltd. It may not be reproduced either in its entirety or in part and it may not be used for advertising. The client to whom the Report is issued may, however, show or send it, or a certified copy thereof prepared by the Hong Kong Standards and Testing Centre Ltd. to his customer, supplier or other persons directly concerned. The Hong Kong Standards and Testing Centre Ltd. will not, without the consent of the client, enter into any discussion of correspondence with any third party concerning the contents of the Report. 2. The report refers only to the sample tested and does not apply to the bulk, unless the sampling has been carried out by the Hong Kong Standards and Testing Centre Ltd. and is stated as such in the Report. 3. In the event of the improper use of the report, the Hong Kong Standards and Testing Centre Ltd. reserves the rights to withdraw it, and to adopt any other remedies which may be appropriate. 4. Samples submitted for testing are accepted on the understanding that the Report issued cannot form the basis of, or be the instrument for, any legal action against the Hong Kong Standards and Testing Centre Ltd. 5. The Hong Kong Standards and Testing Centre Ltd. will not be liable for or accept responsibility for any loss or damage howsoever arising from the use of information contained in any of its Reports or in any communication whatsoever about its said tests or investigations. 6. Applicants wishing to use the Report in court proceedings or arbitration shall inform the Hong Kong Standards and Testing Centre Ltd. to that effect prior to submitting the sample for testing.

香港新界大埔工業邨大宏街10號
10 Dai Wang Street,
Taipo Industrial Estate,
N. T., Hong Kong
Tel : (852) 2666 1888
Fax : (852) 2664 4353
Homepage: www.hkstdc.org
E-mail: hkstdc@hkstdc.com



香 港 標 準 及 檢 定 中 心
Hong Kong Standards and Testing Centre

Date: 2002-10-09

Page 2 of 2

NO: HC117199

TEST RESULT(S):

Sample	Result (including both sides)	Min. coating mass* (including both sides)
225 x 25mm underfloor trunking	251 g/m ²	235 g/m ²

Note: *Limit for Hot-dip zinc coated steel to BS 2989 with a minimum coating designation of G275

SUMMARY:

The submitted sample complied with specification for steel surface cable trunking in accordance with BS 4678: Part 2: 1973 Class 3 protection.

*****End of Document*****

Conditions in issuance of Test Report

1. This Report is issued in confidence to the client and it will be strictly treated as such by the Hong Kong Standards and Testing Centre Ltd. It may not be reproduced either in its entirety or in part and it may not be used for advertising. The client to whom the Report is issued may, however, show or send it, or a certified copy thereof prepared by the Hong Kong Standards and Testing Centre Ltd. to his customer, supplier or other persons directly concerned. The Hong Kong Standards and Testing Centre Ltd. will not, without the consent of the client, enter into any discussion of correspondence with any third party concerning the contents of the Report. 2. The report refers only to the sample tested and does not apply to the bulk, unless the sampling has been carried out by the Hong Kong Standards and Testing Centre Ltd. and is stated as such in the Report. 3. In the event of the improper use of the report, the Hong Kong Standards and Testing Centre Ltd. reserves the rights to withdraw it, and to adopt any other remedies which may be appropriate. 4. Samples submitted for testing are accepted on the understanding that the Report issued cannot form the basis of, or be the instrument for, any legal action against the Hong Kong Standards and Testing Centre Ltd. 5. The Hong Kong Standards and Testing Centre Ltd. will not be liable for or accept responsibility for any loss or damage howsoever arising from the use of information contained in any of its Reports or in any communication whatsoever about its said tests or investigations. 6. Applicants wishing to use the Report in court proceedings or arbitration shall inform the Hong Kong Standards and Testing Centre Ltd. to that effect prior to submitting the sample for testing.

香港新界大埔工業邨大宏街10號
10 Dai Wang Street,
Taipo Industrial Estate,
N. T., Hong Kong
Tel : (852) 2666 1888
Fax : (852) 2664 4353
Homepage: www.hkstc.org
E-mail: hkstc@hkstc.com



2007000102Z



TESTING
CNAS L0095

Page 1 of 16 Pages

No.: GJW2009-0752

检 验 报 告

TEST REPORT

NAME OF SAMPLE: Galvanized steel floor cable trunking

CLIENT: Lik Hung Metal Manufacturing LTD

CLASSIFICATION OF TEST: Commission test



Guangzhou Vkan Certification and Testing Institute (CVC—former GTIHEA)




检验报告

TEST REPORT

No.: GJW2009-0752

Page 2 of 16 pages


Name of product: Galvanized steel floor cable trunking	Trade mark: L.H.
Type/Model: 225×25mm(3/C)×1.6mm underfloor trunking	Sample status: —
Manufacturer: Lik Hung Metal Manufacturing LTD	Commissioned by: Lik Hung Metal Manufacturing LTD
Manufacturer address: 5, Cheung Shun ST., G/F, Cheungshawan, KLN, Hong Kong	Commissioner address: 5, Cheung Shun ST., G/F, Cheungshawan, KLN, Hong Kong
Quantity of sample: 9 pcs	Sampled by: —
Sample identification: —	Sampling at (place): —
Means of receiving: Submitted by the client	Means of sampling: —
Classification of test: Commission test	Sampling date: —
Receiving date: 2009.07.08	Completing date: 2009.09.02
Tested according to: IEC 61084-1:1991+A1:1993 IEC 61084-2-1:2003	Test item: Full test
<p>Test conclusion:</p> <p>The galvanized steel floor cable trunking submitted by the client is tested according to the following standards: IEC 61084-1:1991+A1:1993 Cable trunking and ducting systems for electrical installation Part 1: General requirements IEC 61084-2-1:2003 Cable trunking and ducting systems for electrical installations Part 2-2: Particular requirements-Cable trunking systems and cable ducting systems intended for underfloor and flushfloor installations Test result: pass.</p> <div style="text-align: right;"> Date of issue: 2009.09.02</div>	

Approved by:




Reviewed by:

Meng Zhiqiang



Tested by:

Lu Guowei



Test item particulars:

Material: Galvanized steel
 Mechanical properties: Heavy mechanical stresses
 Temperatures: -5°C
 Flame propagation: Non-flame propagation
 Electrical characteristics: Electrical continuity characteristics
 Ingress of solid objects: N
 Ingress of water: N
 Protection against corrosive or polluting substances: high protection outside and medium protection inside
 Protection against solar radiation: N
 Cover retention of the system: With tools
 Floor treatment: Dry-treatment
 Protection against impacts on floor service units when in use: With protection

Copy of marking plate:


CLASS 3

Summary of testing:

—