



The Hong Kong Standards and Testing Centre Ltd.

Date: 1998-10-22

TEST REPORT

Page 1 of 2

NO: WC3753/306

APPLICANT: (Code: 000774)

Lik Hung Metal Works Ltd
5 Cheung Shun St
G/F Cheung Sha Wan
Kowloon Hong Kong

Attn : Mr C W Chan

DESCRIPTION OF SAMPLE(S):

Two submitted samples said to be :

1. 100 mm hot-dipped galvanized cable tray with 1.6 mm thickness.
2. 450 mm hot-dipped galvanized cable tray with 2.0 mm thickness.

SAMPLE(S) RECEIVED DATE:

1998-10-13

TESTED DATE:

1998-10-16 to 1998-10-21

INVESTIGATION(S) REQUESTED:

Copper sulphate dip test for uniformity of coating on galvanized steel.

METHOD(S) USED:

Ref. BS 729 : 1971 (1986) Appendix B

Clement Au, CFD
For Managing Director

Conditions in Issuance of Test Report
1. This Report is issued in confidence to the client and it will be strictly treated as such by the Hong Kong Standards and Testing Centre Ltd. It may not be reproduced either in its entirety or in part and it may not be used for advertising. The client to whom the Report is issued may, however, show or send it, or a certified copy thereof prepared by the Hong Kong Standards and Testing Centre Ltd. to his customer, supplier or other persons directly concerned. The Hong Kong Standards and Testing Centre Ltd. will not, without the consent of the client, enter into any discussion or correspondence with any third party concerning the contents of the Report. 2. The report refers only to the sample tested and does not apply to the bulk, unless the sampling has been carried out by the Hong Kong Standards and Testing Centre Ltd. and is stated as such in the Report. 3. In the event of the improper use of the report, the Hong Kong Standards and Testing Centre Ltd. reserves the rights to withdraw it, and to adopt any other remedies which may be appropriate. 4. Samples submitted for testing are accepted on the understanding that the Report issued cannot form the basis of, or be the instrument for, any legal action against the Hong Kong Standards and Testing Centre Ltd. 5. The Hong Kong Standards and Testing Centre Ltd. will not be liable for or accept responsibility for any loss or damage howsoever arising from the use of information contained in any of its Reports or in any communication whatsoever about its said tests or investigations. 6. Applicants wishing to use the Report in court proceedings or arbitration shall inform the Hong Kong Standards and Testing Centre Ltd. to that effect prior to submitting the sample for testing.



The Hong Kong Standards and Testing Centre Ltd.

Date: 1998-10-22

Page 2 of 2

NO: WC3753/306

TEST RESULT(S):

<u>Sample</u>	<u>Result</u>
1	Pass
2	Pass

SUMMARY

Both the test results of the submitted sample 1 and 2 were found to comply with BS 729 : 1971, copper sulphate dip test for uniformity of coating on steel articles.

***** End of Document *****