

Lik Hung Metal Manufacturing
23, Kung Yip St, G/F, Hong Kong

Our reference	4324974.00
Author	Byron Huang
Direct line	+86 20 66826404
Telefax	+86 20 66612001
E-mail	byron.huang@dekra-certification.cn
Date	2016-05-09

Subject:

IP66 test report

PRODUCT DATA

Product	:	Wall Mounting Metal Enclosures
Trade mark / Manufacturer	:	ME Waterproof Box, ME box, Metrix box
Type / model	:	ME405020S
Order Number	:	--
Reference Number	:	--
Customer	:	--
Quantity of sample	:	2 pcs
Rated voltage & frequency	:	--
Rated input	:	--
Class	:	--
Degree of protection	:	IP66
Further information	:	--
This Document includes	:	7

TEST STANDARD

The IP66 test carried out based on the following test requirements

IEC 60529:1989 + A1:1999+A2: 2013

CONCLUSION:

Based on the test results given in this report, the construction of the submitted sample **does comply** with above mentioned safety requirements.

TEST RESULTS:

Clause	Requirement	Remarks	Verdict
1	Scope and object		--
2	Normative reference		--
3	Definitions		--
4	Designations		--
5	Degrees of protection against access to hazardous parts and against solid foreign objects indicated by the first characteristic numeral	IP6X	P
6	Degrees of protection against ingress of water indicated by the second characteristic numeral	IPX6	P
7	Degrees of protection against access to hazardous parts indicated by the additional letter		N/A
8	Supplementary letter		N/A
9	Examples of designations with the IP code		N/A
10	Marking		N/A
11	General test requirements		P
12	Test for protection against access to hazardous parts indicated by the first characteristic numeral	IP66	P
13	Test for protection against solid foreign objects indicated by the first characteristic numeral	IP6X. No dust entered.	P
14	Test for protection against water indicated by the second characteristic numeral	IPX6. No water entered.	P
15	Test for protection against access to hazardous parts indicated by the additional letter		N/A

PHOTOS: BEFOR TEST*Overview**Overview**Overview**Overview**Internal view**Internal view*

PHOTOS: BEFOR TEST

PHOTOS: BEFOR TEST

Corner view



Internal view



Joint view



Corner view

PHOTOS: AFTER TEST


	
Setting view	Internal view
	
Internal view	Setting view
	<p data-bbox="1155 1301 1198 1323">NIL</p>
Internal view	NIL

Please note that every statement made in this report is only valid for the sample tested and reported herein.


Trusting to have informed you sufficiently, we remain,
With best regards

DEKRA Testing and Certification (Shanghai) Ltd. Guangzhou Branch

Engineer name : Byron Huang

Engineer signature : 

Reviewed by : Lyne Wang

Reviewer signature : 

-END-